



- NOTES.**
- FUSE:-
FIG.13A } 1.5A PER 10' FA RELAYS } FUSED ON GBW15241 FIG.1 FOR EXCHANGES WITHOUT GROUP FUSE PANELS OTHERWISE FUSED ON ALARM EQUIPT FUSE PANEL ON R.E.R.
FIG.20 }
FIG.15 } 1.5A }
FIG.14 } 1.5A }
FIG.17A } 1.5A PER 10' FB RELAYS }
FIG.19 } & RESIS. R1 }

FIG.18 } 1.5A } FUSE ON FIG.16 OR FIG.17A IF FIG.15 NOT FITTED.
 - FOR EXCHANGES WITH GROUP FUSE PANELS (OR ALARM EQUIPT FUSE PANEL ON R.E.R.) FIT FIG.20 AND WIRING SHOWN 4 FOR OTHER EXCHANGES FIT FIG.13A AND WIRING SHOWN 5
 - OTHER CONTACTS OF ALARM EXTENSION KEY ARE SHOWN ON GBW15800 OR GBW15790 OR EQUIV.
 - THESE TERMINALS ARE REQUIRED ONLY WHEN KEY 'KAE' IS EQUIPPED ON THE TEST RACK OR DESK.
 - FOR FUSE ALARM ARRANGEMENTS R.E.R. SEE GBW15340.
 - WHEN FIG.16 IS PROVIDED ON A.E.R. WIRE 1 TO FIG.17A WHEN FIG.16 IS PROVIDED ON RACKS OTHER THAN A.E.R. WIRE 2 TO FIG.18.
 - THESE TERMINALS ON BATT. STRIP CONN. PROVIDED ONLY WHEN FUSES ARE ON ALARM EQUIPT FUSE PANEL ON R.E.R.
 - FOR WIRING OF FIGS.18 & 21 (ALSO FIG.16 WHEN PROVIDED ON RACKS OTHER THAN A.E.R.) SEE RELEVANT COMMON SERVICES DIAGRAM.
 - ALL WIRING TO BE 22 SW.G. UNLESS OTHERWISE SPECIFIED. PLATE WIRING TO BE 25 SW.G.
 - WHEN 50V HORIZONTAL FUSE PANEL IS REQUIRED ON A.E.R. I.E. WHEN R.E.R. IS FULLY EQUIPPED USE FIG.17B AND ADD WIRING SHOWN 3
 - SHEET 2-2 COVERS ALARM ARRANGEMENTS (WITH OR WITHOUT GROUP FUSE PANELS) AT ANAM/ OR EQUIV. WITH EXTENSION OF ALARMS TO ES118 SCHEMES 2 OR 3.
 - ON SOME EARLIER EQUIPMENT RESISTORS R1, R2, R3 (FIG.16) R2 (FIG.17A) R3 (FIG.17B) WERE P.O. N°12 TYPE.
 - PRIOR TO ISSUE 3, FIG.15 MADE PROVISION FOR AUXILIARY 'AP' RELAY WITH 4 CONTACTS.
 - WHEN THIS CIRCUIT IS USED IN CONJUNCTION WITH GBW15790 TERMINALS SHOWN IN BRACKETS (78) TO BE PROVIDED.
 - ON SOME EARLIER EQUIPT BATTERY WIRING COLOURS WERE BK. OR WHITE

NO CHANGE SHOWN	(152918)	8A	9-9-70	CJM
NO CHANGE SHOWN	(152918)	8A	9-9-70	CJM
NOTE 14 ADDED BATT. WIRE COLOURS CHANGED FROM 8 TO 7	(152918)	8A	1-4-69	22
NOTE 14 & ALT. TAGS ADDED	(152918)	8A	31-10-66	ARM
AMENDMENT PARTICULARS	ISSUE DATE	APP'D	REF.	
GBW 16150	50'			
FUSE ALARM ARRANGEMENTS A.E.R. FOR EXCHANGES WITH R.E.R. (NOTE 11)				
SHEET 2-2				