RELAYS HAVING NO KS DESIGNATIONS WARD LEONARD COMPANY, ALLEN-BRADLEY COMPANY AND WESTINGHOUSE CORPORATION REQUIREMENTS AND ADJUSTING PROCEDURES

1. GENERAL

1.001 This addendum supplements Section 040-811-701, Issue 1.

1.002 This addendum is issued to specify the use of KS-19578 L1 trichloroethane wherever KS-8372 trichloroethylene is now specified. The same precautions that apply for KS-8372 trichloroethylene shall apply to the KS-19578 L1 trichloroethane.